



Tuesday September 5<sup>th</sup>, 2017

**RE: Results of Annual Water Quality Testing**

School Name	Range of Lead (µg/L)	Exceedances
Conrad Elementary	0.00393 to 0.00702	0 out of 5
Pineridge Elementary	0.0024 to 0.0074	0 out of 5
École Roosevelt Park Community School	0.00219 to 0.00641	0 out of 5
Prince Rupert Middle School	0.0025 to 0.00659	0 out of 6
Pacific Coast School	0.0033 to 0.00633	0 out of 2
Wap Sigatgyet	0.00828	0 out of 1
Operations Building	0.00199	0 out of 1
Port Edward Community School	<0.00020 to 0.00024	0 out of 3
Lax Kxeen Elementary School	0.00293 to 0.00315	0 out of 2
Charles Hays Secondary School	0.00161 to 0.0096	0 out of 3
<b>Guideline for Canadian Drinking Water</b>	<b>0.01</b>	<b>NA</b>

**Note:**

- Two exceedances were recorded in the district during this reporting term. Both were remediated by extending automatic flush times prior to retesting to verify drinking water acceptability.
- Sampling was completed August 2017.
- Lab analysis was performed by Northern Laboratories Ltd.
- Analysis, testing planning, execution & reporting was conducted as per Health Canada Guidance on Controlling Corrosion in Drinking Water Distribution Systems and in partnership and with Northern Health.