

****UPDATE May 2020 - SD 52 Fountain Test Results**

Location	Amount of Detectible Lead Milligrams per litre (mg/L) MAC .005 (no exceedances)	Amount of Detectible Copper milligrams per litre (mg/L) MAC 2.0 (some exceedances)
Lax 4-11	0.00050	0.0243
Lax 4-12	0.00055	0.0203
Lax Staff Sink (cold water)	0.00288	0.1050
New Guideline for Canadian Drinking Water	0.005 mg/L	2.0 mg/L
Old Guideline for Canadian Drinking Water	0.01 mg/L	N/A

* Lax Kxeen fountains are open for school use