

****UPDATE April 2020 - SD 52 Fountain Test Results**

Location	Amount of Detectible Lead Milligrams per litre (mg/L) MAC .005 (no exceedances)	Amount of Detectible Copper milligrams per litre (mg/L) MAC 2.0 (some exceednacees)
Pine 1-1	0.00046	0.0765
Pine 1-2	< .00020	0.179
Pine 1-3	0.00039	0.92
Pine Staff Room Sink (*cold water tap only)	0.00241	0.12
New Guideline for Canadian Drinking Water	0.005 mg/L	2.0 mg/L
Old Guideline for Canadian Drinking Water	0.01 mg/L	N/A

* Pineridge fountains are open for school use