

SD 52 Fountain Test Results

Location	Amount of Detectible Lead Milligrams per litre (mg/L) MAC .005 (no exceedances)	Amount of Detectible Copper milligrams per litre (mg/L) MAC 2.0 (some exceedances)
Pine 1-1	0.00058	0.3730
Pine 1-2	0.00149	0.3600
Pine 1-3	0.00045	0.562
Roose 2-4	0.00061	0.8130
Roose 2-5	0.00077	0.3400
Roose 2-6	0.00076	0.9310
Roose 2-7	0.00034	1.2700
PRMS 3-8	0.00022	0.1770
PRMS 3-9	0.00033	0.2590
PRMS 3-10	0.00046	0.2590
Lax 4-11	0.00063	0.6340
Lax 4-12	0.00048	0.3090
Con 5-13	0.00032	0.0360
Con 5-14	0.00139	0.3240
CHSS 6-15	<0.00020	1.3400
CHSS 6-16	0.00026	0.4440
CHSS 6-17	<0.00020	0.2320
CHSS 6-18	0.00021	0.3520
New Guideline for Canadian	0.005 mg/L	2.0 mg/L
Old Guideline for Canadian	0.01 mg/L	N/A

* No exceedences of lead detected in drinking water

* No Exceedences of copper detected in district fountains

* As directed by Northern Health,during boil water notices or water quality advisories fountains were put out of service and bottled drinking water supplied across the District